


TEST REPORT

To:	Huawei Technologies Co., Ltd
Attn:	zhouzhengyou
Address:	Administration Building, Headquarters of Huawei Technologies Co., Ltd., Bantian, Longgang District, Shenzhen, 518129, P.R.C
Fax/E-mail:	0755- 89650226

This document includes: 6 pages

Factory name:	Huawei Technologies Co., Ltd		
Location:	Administration Building, Headquarters of Huawei Technologies Co., Ltd., Bantian, Longgang District, Shenzhen, 518129, P.R.C	Sample No:	GZ171127/006-Q02N01GZ99
	Start date:	01 December, 2017	
	Finish date:	01 December, 2017	
	Standards used: (Date):	IEC 60529:1989+A1:1999 +A2:2013	
	Clauses examined:	IEC 60529:1989+A1:1999 +A2:2013 (cl.12) IP6X test (cl.13.6) IP6X test (cl.14.2.5) IPX5 test	
	Re-testing:	--	
<p style="text-align: center;">SOLAR INVERTER</p> <p>Model : SUN2000-33KTL-A, SUN2000-43KTL-IN-C1, SUN2000-36KTL, SUN2000-42KTL, SUN2000-50KTL, SUN2000-50KTL-C1, SUN2000-40KTL-JP, SUN2000-33KTL-JP</p>		Remark / Note:	None

CONCLUSION: Pass

Test done by,	Approved by,
Function	Function
Name: Jacky LI; Date: 01 December, 2017	Name: Andy CHEN; Date: 01 December, 2017

This report is governed by, and incorporates by reference, the Conditions of Testing as posted at the date of issuance of this report at <http://www.bureauveritas.com/cps> and is intended for your exclusive use. Any copying or replication of this report to or for any other person or entity, or use of our name or trademark, is permitted only with our prior written permission. This report sets forth our findings solely with respect to the test samples identified herein. The results set forth in this report are not indicative or representative of the quality or characteristics of the lot from which a test sample was taken or any similar or identical product unless specifically and expressly noted. Our report includes all of the tests requested by you and the results thereof based upon the information that you provided to us. You have 60 days from date of issuance of this report to notify us of any material error or omission caused by our negligence, provided, however, that such notice shall be in writing and shall specifically address the issue you wish to raise. A failure to raise such issue within the prescribed time shall constitute your unqualified acceptance of the completeness of this report, the tests conducted and the correctness of the report contents.

TEST REPORT N°: BVCZ17N00149HTGC
HISTORICAL OF REMARK-NOTE
None

PICTURES OF THE SAMPLE TESTED


Sample before testing



Testing for IP6X




TEST REPORT N°: BVCZ17NO0149HTGC



Testing for IPX5





After testing IP65



TEST REPORT N°: BVCZ17N00149HTGC

Possible test case verdicts:	
- test object does meet the requirement :	P (Pass)
- test case does not apply to the test object :	NA (Not applicable)
- test object does not meet the requirement :	F (Fail)
- test object does not demand	ND (Not demanded)
General remarks:	
"(See remark #)" refers to a remark appended to the report.	
Throughout this report a comma is used as the decimal separator.	

CLAUSES	TITLE	REMARK	NOTE	PASS	FAIL	N.A
12.3.1	TEST FOR FIRST CHARACTERISTIC NUMERAL 6 FOR PROTECTION AGAINST ACCESS TO HAZARDOUS PARTS	Access probes for the tests for protection of persons against access to hazardous parts <small>Test wire 1.0 mm diameter, 100 mm long</small> 	Test wire is not access to hazardous parts	X		
13.6.2	TEST FOR FIRST CHARACTERISTIC NUMERAL 6 FOR PROTECTION AGAINST SOLID FOREIGN OBJECTS		There is no dust be observed	X		
14.2.5	TEST FOR SECOND CHARACTERISTIC NUMERAL 5 FOR PROTECTION AGAINST WATER		There is no water be observed	X		
N.A: Not applicable						

--End of this report--

Bureau Veritas Consumer Products Services (Guangzhou) Co., Ltd. Science City Branch

Rm.101,G5 Building, South China Advanced Materials Innovation Park, NO.31 Kefeng Rd, Guangzhou Science City, Guangzhou, 510663 China

Tel: +86 20-87148500
 Fax: +86 20-87148528
 Email: bvcpstech.GZ@cn.bureauveritas.com