

Certificate of compliance

Applicant: Huawei Technologies Co., Ltd.

Administration Building, Headquarters of Huawei Technologies Co., Ltd., Bantian, Longgang District,

Shenzhen, 518129

P.R. China

Product: Automatic disconnection device between a generator and the

public low-voltage grid

Model: SUN2000-8KTL

SUN2000-10KTL SUN2000-12KTL SUN2000-15KTL SUN2000-17KTL SUN2000-20KTL SUN2000-23KTL SUN2000-28KTL

Use in accordance with regulations:

Automatic disconnection device with three-phase mains surveillance in accordance with EN 50438:2007 for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverters.

Applied rules and standards:

EN 50438:2007

Requirements for the connection of micro-generators in parallel with the public low-voltage distribution networks.

DIN V VDE V 0126-1-1 (VDE V 0126-1-1):2006-02

Automatic disconnection device between a generator and the public low-voltage grid

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number: PV140401N028-EN50438

Certificate number: U15-0278
Date of issue: 2015-08-13

Certification body

Dieter Zitzmann

DAKKS

Deutsche
Akkreditierungsstelle
D-ZE-12024-01-01

Certification body of Bureau Veritas Consumer Products Services Germany GmbH Accredited according to EN 45011 - ISO / IEC Guide 65