



**BUREAU  
VERITAS**

# Certificate for the NS protection

**Manufacturer /  
applicant:**

**Huawei Technologies Co., Ltd.  
Administration Building, Headquarters of Huawei Technologies Co., Ltd.,  
Bantian, Longgang District, Shenzhen, 518129,  
P.R.C**

<b>Type of grid and plant protection:</b>	<b>Integrated NS protection</b>
<b>Assigned to generation unit type:</b>	<b>SUN2000-100KTL-M1</b>

**Firmware version:** V500R001

**Connection rule:** VDE-AR-N 4105:2018-11 – Power generation systems connected to the low-voltage distribution network

Technical minimum requirements for the connection to and parallel operation with low-voltage distribution networks.

**Applicable standards / directives:** DIN VDE V 0124-100 (VDE V 0124-100):2019-09 – Grid integration of power generation systems – low voltage

Test requirements for power generation units to be connected and operated parallel with the low-voltage distribution networks

**The above mentioned grid and plant protection has been tested and certified according to the test guideline VDE 0124-100. The electrical properties required in the connection rule are satisfied.**

- Setting values and disconnect times
- Properly functioning functional chain "NS protection – interface switch"
- Technical requirements of the switching device
- Active detection of stand-alone power systems
- Single-fault tolerance

**The certificate contains the following information:**

- Technical specifications of the NS protection and corresponding power generation type
- Setting values of the protection functions
- Trip values of the protection functions

**BV project number:** PVDE190905N026-R1

**Certification program:** NSOP-0032-DEU-ZE-V01

**Certificate number:** U20-0142

**Date of issue:** 2020-03-13

**Certification body**



**Holger Schaffer**



Certification body of Bureau Veritas Consumer Products Services Germany GmbH Accredited according to DIN EN ISO/IEC 17065

A partial representation of the certificate requires the written permission of Bureau Veritas Consumer Products Services Germany GmbH

**E.7 Requirements for the test report for the NS protection**

Extract from test report for NS protection

Nr. PVDE190905N026-R1

“Determination of electrical properties”

**NS protection as integrated NS protection**

<b>Manufacturer / applicant:</b>	Huawei Technologies Co., Ltd. Administration Building, Headquarters of Huawei Technologies Co., Ltd., Bantian, Longgang District, Shenzhen, 518129, P.R.C
<b>Type of grid and plant protection:</b>	Integrated NS protection
<b>Assigned to generation unit type:</b>	SUN2000-100KTL-M1
<b>Firmware version:</b>	V500R001
<b>Integrated interface switch:</b>	Typ Schalteinrichtung 1: Relais Typ Schalteinrichtung 2: Relais
<b>Measurement period:</b>	2019-09-05 - 2019-12-03

**Inverter (phase to neutral)**

Protection function	Setting value	Trip value	Disconnection time <sup>a</sup>
Voltage drop protection U <	184,0 V	183,7 V	3085 ms
Voltage drop protection U <<	103,5 V	103,8 V	372 ms
Rise-in-voltage protection U >	253,0 V	--	513 s <sup>b</sup>
Rise-in-voltage protection U >>	287,5 V	287,2 V	179 ms
Frequency decrease protection f <	47,50 Hz	47,50 Hz	180 ms
Frequency increase protection f >	51,50 Hz	51,50 Hz	179 ms

**Inverter (phase to phase)**

Protection function	Setting value	Trip value	Disconnection time <sup>a</sup>
Voltage drop protection U <	318,7 V	320,5 V	3088 ms
Rise-in-voltage protection U >	179,3 V	180,5 V	394 ms
Rise-in-voltage protection U >>	438,2 V	--	513 s <sup>b</sup>
Frequency decrease protection f <	498,0 V	500,8 V	177 ms
Frequency increase protection f >	47,50 Hz	47,50 Hz	180 ms

<sup>a</sup> proper time of interface switch 30 ms

<sup>b</sup> longest disconnection of the rise-in-voltage protection as a moving 10-minute-average, tested according clause 5.5.7 Protection devices and protection settings of VDE 0124-100

The disconnect time (sum of trip time of grid and plant protection and delay time of interface switch) must not exceed 200 ms.

A check of the overall functional chain "NS protection – interface switch" resulted in a successful disconnection.

The above mentioned grid and plant protection with the assigned power generation units has met the requirements for islanding detection with the help of the active method (resonant circuit test).

The above mentioned NS protection meets the requirements for synchronization.