



Product Service

Compliance Document

No. D 041829 3243 Rev. 00

Holder of Certificate: **Huawei Technologies Co., Ltd.**
Administration Building
Headquarters of Huawei Technologies Co., Ltd.
Bantian, Longgang District
518129 Shenzhen
PEOPLE'S REPUBLIC OF CHINA

Product: **Converter**
SOLAR INVERTER

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. See also notes overleaf.

Test report no.: 704091824403-00

Date, 2018-08-03 (Zhengdong Ma)

TUV SUD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD
ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT



Product Service

Compliance Document

No. D 041829 3243 Rev. 00

Model(s): SUN2000-36KTL, SUN2000-42KTL

Parameters:

d.c. Max. Input Voltage:	1100 Vd.c.
d.c. MPP Range:	200-1000 Vd.c.
d.c. Max. Input Current:	22 A /22 A /22 A /22 A
Isc PV:	30 A /30 A /30 A /30A
a.c. Output Nominal Voltage:	For model SUN2000-36KTL: 3/N/PE~, 400 V 3~, 400 V (optional) For model SUN2000-42KTL: 3~, 480V
a.c. Nominal Operating Frequency:	50 Hz
a.c. Output Max. Current:	For model SUN2000-36KTL: 57,8 A For model SUN2000-42KTL: 56,6 A
a.c. Output Rated Power:	36 kVA (SUN2000-36KTL) 42 kVA (SUN2000-42KTL)
a.c. Output Max. Power:	40 kVA (SUN2000-36KTL) 47 kVA (SUN2000-42KTL)
Power Factor(adj.):	0,8(lagging)...0,8(leading)
Operating Temperature Range:	-25 °C...+60 °C
Protective Class:	I
Ingress Protection:	IP65

Tested according to: IRR-DCC-MV:2015(Version 1)

TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD TÜV SÜD
 ZERTIFIKAT ♦ CERTIFICATE ♦ 認證證書 ♦ CERTIFICADO ♦ CERTIFICAT