



# Certificate of Conformity

**Certificate No.:** 2088AP0511N092004

**Product:** SOLAR INVERTER

**Brand Name:**



HUAWEI

**Test Model No.:**

SUN2000-15KTL-M3, SUN2000-17KTL-M3, SUN2000-20KTL-M3,  
SUN2000-23KTL-M3, SUN2000-28KTL-M3, SUN2000-30KTL-M3,  
SUN2000-36KTL-M3, SUN2000-40KTL-M3, SUN2000-42KTL-M3

**Applicant:**

Huawei Technologies Co., Ltd.

Administration Building, Headquarters of Huawei Technologies Co., Ltd.,  
Bantian, Longgang District, Shenzhen, 518129, P.R.C

**Report No.:**

PVFR200511N092

## Use in accordance with regulations:

Automatic disconnection device with three-phases mains surveillance in accordance with DIN V VDE V 0126-1-1/A1 VFR2014, DIN V VDE V 0126-1-1/A1 VFR2019 (Protection of production installations connected to the public distribution network, ERDF-NOI-RES\_13E, Version 7, 14/12/2018), for photovoltaic systems with a three-phases parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter. This serves as a replacement for the disconnection device with isolating function that can access the distribution network provider at any time.

## Applied rules and standards

**UTE C15-712-1:2013-07, UTE C 15-712-1:2010-07, rectificatif 0:2010-09 et rectificatif 1:2012-02**

Photovoltaic installations connected to the public distribution network

**DIN V VDE V 0126-1-1/A1:2012-02**

Automatic disconnection device between a generator and the public low-voltage grid; Amendment 1.

The safety concept of an aforementioned representative product corresponds at the time of issue of this attestation to valid safety specifications for the specified use in accordance with regulations.



**Name: James Huang**  
**Technical Manager/ New Energy Team**  
**Date: 2020-07-31**

This document shall not be reproduced, except in full, without the written approval of  
Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch.

Information given in this document is related to the tested specimen of the described electrical sample.