



**BUREAU
VERITAS**

ATTESTATION of conformity with European Directives

Attestation Number: **1888AB0827N015001**
 Product: **SOLAR INVERTER**
 Brand Name: **Huawei**
 Model: **SUN2000-60KTL-M0**
 Additional Model: **SUN2000-50KTL-M0**
 Applicant: **Huawei Technologies Co., Ltd.**
 Address: **Administration Building, Headquarters of Huawei Technologies Co., Ltd.,
 Bantian, Longgang District, Shenzhen, 518129, P.R.C**



Parameter	SUN2000-60KTL- M0	SUN2000-50KTL-M0
MPPT Input	DC 200-1000V, 22A*6 67400W	DC 200-1000V, 22A*6 56200W
Output	220Vac/380Vac, 230Vac/400Vac, 3(N)W+PE 277Vac/480Vac ; 3W+PE, 50/60Hz, 60kW	220Vac/380Vac, 230Vac/400Vac, 240Vac/415Vac, 3(N)W+PE, 50/60Hz, 50kW
Max	100A for 380Vac, 95.3A for 400Vac, 79.4A for 480Vac, 66kVA	83.6A for 380Vac, 79.4A for 400Vac, 76.6A for 415Vac, 55kVA
Power	60kW	50kW
RS485	Support	Support
PLC	Support	Support
PID	Support	Support
USB Smart Dongle	Support	Support

The submitted sample of the above equipment has been tested for  marking according to following European Directive and standards:
 -Electromagnetic Compatibility Directive 2014/30/EU

Standards	Report Number	Report date
EN 61000-6-3:2007 + A1:2011(*) EN 61000-6-4:2007 + A1:2011 EN 61000-3-12:2011 EN 61000-3-11:2000 EN 61000-6-1:2007 EN 61000-6-2:2005	CE180827N015	Sep. 26, 2018

* The PLC communication mode or AC 480V power supply mode of Solar Inverter is not apply to this standard.

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive.

This verification does not imply assessment of the production of the product. The  marking may be affixed if all relevant and effective European Directives with  are applicable.

**Supervisor
EMC Department**



**Name: Madison Luo
Data: Sep. 26, 2018**

This document shall not be reproduced, except in full, without the written approval of
Bureau Veritas Shenzhen Co., Ltd.

Information given in this document is related to the tested specimen of the described electrical sample.