



**Bureau Veritas**  
**Consumer Products Services**  
**Germany GmbH**  
Businesspark A96  
86842 Türkheim  
Germany  
+ 49 (0) 40 740 41 – 0  
cps-tuerkheim@de.bureauveritas.com

Certification body of BV CPS GmbH  
Accredited according to EN 45011 -  
ISO / IEC Guide 65

## Certificate of compliance

**Applicant:** **Huawei Technologies Co., Ltd.**  
Administration Building, Headquarters of Huawei  
Technologies Co., Ltd., Bantian, Longgang District,  
Shenzhen, 518129,  
P.R. China

**Product:** **Automatic disconnection device between a generator and  
the public low-voltage grid**

**Model:** **SUN2000-12KTL; SUN2000-15KTL;  
SUN2000-17KTL; SUN2000-20KTL**

### Use in accordance with regulations:

Automatic disconnection device with three-phase mains surveillance in accordance with Engineering Recommendation G59/2 for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter. This serves as a replacement for the disconnection device with isolating function that can access the distribution network provider at any time.

### Applied rules and standards:

DIN V VDE V 0126-1-1:2006-02 (Redundancy) and Engineering Recommendation G59/2: The SUN2000-12KTL; SUN2000-15KTL; SUN2000-17KTL; SUN2000-20KTL are rated >16A and ≤ 50kW (3 phase).

The default values for "Small Power Stations" on the low-voltage grid were verified.

Distribution Code: Modification to the Distribution Code to implement a change to Engineering Recommendation G59/2 relating to the limits of DC injection April 2011

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

**Report number:** PVUK130106N018-1-G59/2  
**Certificate number:** U13-0058  
**Date of issue:** 2013-02-02    **Valid until:** 2016-02-01

### Certification body

Dieter Zitzmann

