

TCB

**GRANT OF EQUIPMENT
AUTHORIZATION**

TCB

Certification

**Issued Under the Authority of the
Federal Communications Commission**

By:

**ACB, Inc.
6731 Whittier Avenue Suite C110
McLean, VA 22101**

Date of Grant: 07/14/2017

Application Dated: 07/05/2017

**Huawei Technologies Co.,Ltd
Administration Building, Headquarters of Huawei
Technologies Co., Ltd., Bantian, Longgang District
Shenzhen,
China**

Attention: Zhang Xinghai

NOT TRANSFERABLE


EQUIPMENT AUTHORIZATION is hereby issued to the named GRANTEE, and is VALID ONLY for the equipment identified hereon for use under the Commission's Rules and Regulations listed below.

FCC IDENTIFIER: QIS45KTLUSPLC
Name of Grantee: Huawei Technologies Co.,Ltd
Equipment Class: Access Broadband Over Powerline System
Notes: Solar Inverter

<u>Grant Notes</u>	<u>FCC Rule Parts</u>	<u>Frequency Range (MHZ)</u>	<u>Output Watts</u>	<u>Frequency Tolerance</u>	<u>Emission Designator</u>
	15G	2.5 - 5.7			

Class II Permissive Change for minor changes.

This device is only approved for installations where the BPL device is mounted in, or attached to, a pad mounted transformer housing or a ground-mounted junction box.



TCB

**GRANT OF EQUIPMENT
AUTHORIZATION**

TCB

**Certification
Issued Under the Authority of the
Federal Communications Commission
By:**

**ACB, Inc.
6731 Whittier Avenue Suite C110
McLean, VA 22101**

**Date of Grant: 01/09/2017
Application Dated: 01/05/2017**

**Huawei Technologies Co.,Ltd
Administration Building, Headquarters of Huawei
Technologies Co., Ltd., Bantian, Longgang District
Shenzhen,
China**

Attention: Zhang Xinghai

NOT TRANSFERABLE

EQUIPMENT AUTHORIZATION is hereby issued to the named GRANTEE,
and is VALID ONLY for the equipment identified hereon for use under the
Commission's Rules and Regulations listed below.

FCC IDENTIFIER: QIS45KTLUSPLC
Name of Grantee: Huawei Technologies Co.,Ltd
**Equipment Class: Access Broadband Over Powerline
System**
Notes: Solar Inverter

Grant Notes

FCC Rule Parts
15G

Frequency Range (MHZ) Output Watts Frequency Tolerance
2.5 - 5.7

Emission Designator

This device is only approved for installations where the BPL device is mounted in, or
attached to, a pad mounted transformer housing or a ground-mounted junction box
and couples directly only to underground cables.

