

CERTIFICATE OF COMPLIANCE

Certificate Number 20180510-E479199
Report Reference E479199-20180510
Issue Date 2018-June-14

Issued to: Huawei Technologies Co., Ltd.
Administration Building
Headquarters of Huawei Technologies Co., Ltd.
Bantian, Longgang District
Shenzhen
Guangdong 518129 CHINA

This is to certify that representative samples of Photovoltaic Grid Support Utility Interactive Inverter
Models SUN2000-11.4KTL-USL0, SUN2000-10KTL-USL0, SUN2000-9KTL-USL0

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 1741, Standard for Safety for Inverters, Converters, Controllers and Interconnection System Equipment for Use With Distributed Energy Resources, UL 1741, Second Edition, dated January 28, 2010. Including the requirements in UL 1741 Supplement SA, sections as noted in the Technical considerations.
IEEE 1547, IEEE Standard for Interconnecting Distributed Resources with Electric Power Systems.
IEEE 1547.1, IEEE Standard for Conformance Test Procedures for Equipment Interconnecting Distributed Resources with Electric Power Systems.
UL 62109-1, Safety of Converters for Use in Photovoltaic Power Systems - Part 1: General Requirements; IEC 62109-2, Safety of Power Converters for use in Photovoltaic Power Systems - Part 2: Particular Requirements for Inverters.
CSA C22.2 No. 107.1-16, General Use Power Supplies.

Additional Information:

See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20180510-E479199
Report Reference E479199-20180510
Issue Date 2018-June-14

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Standards for Safety:

UL 1741, Standard for Safety for Inverters, Converters, Controllers and Interconnection System Equipment for Use With Distributed Energy Resources, UL 1741, Second Edition, dated January 28, 2010. Including the requirements in UL 1741 Supplement SA, sections as noted in the Technical considerations.

IEEE 1547, IEEE Standard for Interconnecting Distributed Resources with Electric Power Systems.

IEEE 1547.1, IEEE Standard for Conformance Test Procedures for Equipment Interconnecting Distributed Resources with Electric Power Systems.

UL 62109-1, Safety of Converters for Use in Photovoltaic Power Systems - Part 1: General Requirements.

CSA C22.2 No. 107.1-16, General Use Power Supplies.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20180510-E479199
Report Reference E479199-20180510
Issue Date 2018-June-14

Components covered by this certificate provide functionality in compliance with UL 1741 Supplement A (SA) when used in a UL Listed end product which has been evaluated by UL for its intended purpose. Compliance testing was conducted on samples of the products according to the test methods in the following sections of UL 1741 with compliant results:

Certified functions. Cross Reference table – UL 1741 SA to SRD	Source Requirement Document(s)	Test Standard(s) and Section(s)	Report Date
ANTI-ISLANDING PROTECTION - UNINTENTIONAL ISLANDING WITH GRID SUPPORT FUNCTIONS ENABLED	Electric Rule No. 21 Hh.1a	UL 1741 SA 8	2018-May-10
LOW/HIGH VOLTAGE RIDE THROUGH	Electric Rule No. 21 Table Hh.1	UL 1741 SA 9	2018-May-10
LOW/HIGH FREQUENCY RIDE THROUGH	Electric Rule No. 21 Table Hh.2	UL 1741 SA10	2018-May-10
RAMP RATES	Electric Rule No. 21 Table Hh.2k	UL 1741 SA 11	2018-May-10
RECONNECT BY "SOFT START"	Electric Rule No. 21 Hh.2k	UL 1741 SA 11	2018-May-10
SPECIFIED POWER FACTOR	Electric Rule No. 21 Hh.2i	UL 1741 SA 12	2018-May-10
DYNAMIC VOLT/VAR OPERATIONS	Electric Rule No. 21 Hh.2J	UL 1741 SA 13	2018-May-10
FREQUENCY-WATT	Electric Rule No. 21 Hh.2.L	UL 1741 SA 14	2018-May-10
VOLT-WATT	Electric Rule No. 21 Hh.2.m	UL 1741 SA 15	2018-May-10

Testing conducted to the requirements of UL 1741 SA corresponds to the minimum requirements for CA Rule 21, 2015. An enumeration of functions tested, including complete ratings, and available certified settings for the Grid Support functions, are recorded in the appendix to this document. Test data and detailed results of compliance testing are retained in the complete UL Report for this product.



Bruce Mahrenholz, Director North American Certification Program
 UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20180510-E479199
Report Reference E479199-20180510
Issue Date 2018-June-14

Appendix

Detailed Testing Summary	Test Standard(s) and Section(s)	Fixed / Adjustable	Pass / Fail
UNINTENTIONAL ISLANDING WITH GRID SUPPORT FUNCTIONS ENABLED	UL 1741 SA 8	Adjustable	Pass
HIGH VOLTAGE RIDE-THROUGH DURATION	UL 1741 SA 9.1	Adjustable	Pass
HIGH VOLTAGE RIDE-THROUGH / MUST TRIP MAGNITUDES	UL 1741 SA 9.2	Adjustable	Pass
HIGH VOLTAGE MUST TRIP CLEARING TIMES	UL 1741 SA 9.2	Adjustable	Pass
LOW VOLTAGE RIDE-THROUGH DURATION	UL 1741 SA 9.1	Adjustable	Pass
LOW VOLTAGE RIDE-THROUGH / MUST TRIP MAGNITUDES	UL 1741 SA 9.2	Adjustable	Pass
LOW VOLTAGE MUST TRIP CLEARING TIMES	UL 1741 SA 9.2	Adjustable	Pass
HIGH FREQUENCY RIDE-THROUGH DURATION	UL 1741 SA10.1	Adjustable	Pass
HIGH FREQUENCY RIDE-THROUGH / MUST TRIP MAGNITUDES	UL 1741 SA10.2	Adjustable	Pass
HIGH FREQUENCY MUST TRIP CLEARING TIMES	UL 1741 SA10.2	Adjustable	Pass
LOW FREQUENCY RIDE-THROUGH DURATION	UL 1741 SA10.1	Adjustable	Pass
LOW FREQUENCY RIDE-THROUGH / MUST TRIP MAGNITUDES	UL 1741 SA10.2	Adjustable	Pass
LOW FREQUENCY MUST TRIP CLEARING TIMES	UL 1741 SA10.2	Adjustable	Pass
NORMAL RAMP RATE	UL 1741 SA 11.2	Adjustable	Pass
"SOFT START" RAMP RATE	UL 1741 SA 11.4	Adjustable	Pass
SPECIFIED POWER FACTOR	UL 1741 SA 12	Adjustable	Pass
VOLT/VAR MODE (Q(V))	UL 1741 SA 13	Adjustable	Pass
FREQUENCY-WATT (FW)	UL 1741 SA 14	Adjustable	Pass
VOLT-WATT (VW)	UL 1741 SA 15	Adjustable	Pass



Bruce Mahrenholz, Director North American Certification Program
 UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20180510-E479199
Report Reference E479199-20180510
Issue Date 2018-June-14

Inverter Firmware Version:		
UL 1998 (grid support)	Date	Version/Revision
Yes	2018-01-04	V100R001D00

Inverter Ratings - Output	SUN2000-11.4KTL-USL0	
Output phase configuration	Split phase	Split phase
Nominal (line to line) output voltage V ac	208 V	240 V
Operating voltage range V ac	184-220 V	212-254 V
Normal out frequency Hz	60 Hz	60 Hz
Rated output current (A ac)	47.5 A	47.5 A
Rated output power, (kW)	9.9 kVA	11.4 kVA
Max. Branch Circuit overcurrent protection (A ac)	60 A	60 A
Maximum Air Ambient (°C)	60 °C	60 °C

Inverter Ratings - Output	SUN2000-10KTL-USL0	
Output phase configuration	Single phase	Split phase
Nominal (line to line) output voltage V ac	208 V	240 V
Operating voltage range V ac	184-220 V	212-254 V
Normal out frequency Hz	60 Hz	60 Hz
Rated output current (A ac)	41.7 A	41.7 A
Rated output power, (kW)	8.7 kVA	10 kVA
Max. Branch Circuit overcurrent protection (A ac)	50 A	50 A
Maximum Air Ambient (°C)	60 °C	60 °C

Inverter Ratings - Output	SUN2000-9KTL-USL0	
Output phase configuration	Single phase	Split phase
Nominal (line to line) output voltage V ac	208 V	240 V
Operating voltage range V ac	184-220 V	212-254 V
Normal out frequency Hz	60 Hz	60 Hz
Rated output current (A ac)	37.5 A	37.5 A
Rated output power, (kW)	7.8 kVA	9.0 kVA
Max. Branch Circuit overcurrent protection (A ac)	50 A	50 A
Maximum Air Ambient (°C)	60 °C	60 °C



Bruce Mahrenholz, Director North American Certification Program
 UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20180510-E479199
Report Reference E479199-20180510
Issue Date 2018-June-14

Other ratings:	
Max. output fault current (A) / duration (ms)	62 Arms, 280 Apeak for 29 ms
Max. utility backfeed current to PV input (A)	92Arms,243Apeak for12 ms
Line Synchronization Characteristics / In-rush current	Method 2 / 4.7Arms
Limits of accuracy of voltage measurement	+/- 1 % (of Volts nominal)
Limits of accuracy of frequency measurement	+ /- 0.02 Hz
Manufacturers stated accuracy of time response for voltage trips	1% + 50ms
Manufacturers stated accuracy of time response for frequency trips	1% + 50ms
Enclosure Ratings	IP 65; Type 4X



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20180510-E479199
Report Reference E479199-20180510
Issue Date 2018-June-14

INTERCONNECTION INTEGRITY TEST CATEGORIES:	
C62.42.2 Ring Wave Surge Category	Category B (6kV, 500A)
C62.42.2 Combination Wave Surge Category	Category B (6kV, 3kA)
C37.90.1 RF Immunity - compliance	Yes
C37.90.2 Communication circuit - compliance	Yes

<u>Magnitude and time Limits</u> - Utility interconnection voltage magnitude limits, Ride Through time limits and trip times:						
Nominal voltage	Single / Split phase					
UL 1741 SA9:	Magnitudes (% of nominal)		Ride Through (Seconds) (+)		Must Trip (Seconds)	
Boundary designation (++)	Min	Max	Min	Max	Min	Max
HV3	N/A	N/A	N/A	N/A	N/A	N/A
HV2	110 %	120 %	N/A	N/A	0.16	0.16
HV1	110 %	120 %	0.92	12.0	1.0	13.0
LV1	50 %	88 %	20.0	49.0	21.0	50.0
LV2	50 %	88 %	10.0	49.0	11.0	50.0
LV3	50 %	50 %	0.32	0.42	0.5	21.0

<u>Magnitude and time Limits</u> - Utility interconnection Frequency magnitude limits, Ride Through time limits and trip times:						
Nominal Frequency:	60 Hz					
UL 1741 SA10:	Magnitudes (Frequency)		Ride Through (Seconds) (+)		Must Trip (Seconds)	
Boundary designation	Min	Max	Min	Max	Min	Max
HF3	N/A	N/A	N/A	N/A	N/A	N/A
HF2	62.0	66.0	N/A	N/A	0.16	1000.0
HF1	60.1	66.0	1.0	999.0	2.0	1000.0
LF1	50.0	59.9	1.0	999.0	2	1000.0
LF2	50.0	57.0	N/A	N/A	0.16	1000.0
LF3	N/A	N/A	N/A	N/A	N/A	N/A



Bruce Mahrenholz, Director North American Certification Program
 UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20180510-E479199
Report Reference E479199-20180510
Issue Date 2018-June-14

SA11 Ramp Rate test ratings (RR/SSRR)		
Minimum normal ramp-up rate	1.0 %	%Irated/SEC
Maximum normal ramp-up rate	100 %	%Irated/SEC
Minimum soft start ramp-up rate	0.1 %	%Irated /SEC
Maximum soft start ramp-up rate	100 %	%Irated /SEC

SA12 SPF Specified Power Factor (INV3)	
Minimum Inductive (Underexcited) Power Factor (<0)	- 0.8
Minimum Capacitive (Overexcited) Power Factor (>0)	+ 0.8

SA13 Volt/Var Mode (VV) extent of curve range settings Model: SUN2000-11.4KTL-USL0 240V				
Settings		Qmax Values - Maximums	Qmin Values - Minimums	Units
Reactive power production setting	Q ₁	6840	0	VAR
Reactive power absorption setting at the left edge of the deadband	Q ₂	6840	-6840	VAR
Reactive power absorption setting at the right edge of the deadband	Q ₃	6840	-6840	VAR
Reactive power absorption setting	Q ₄	0	-6840	VAR

SA13 Volt/Var Mode (VV) extent of curve range settings Model: SUN2000-11.4KTL-USL0 208V				
Settings		Qmax Values - Maximums	Qmin Values - Minimums	Units
Reactive power production setting	Q ₁	5940	0	VAR
Reactive power absorption setting at the left edge of the deadband	Q ₂	5940	-5940	VAR
Reactive power absorption setting at the right edge of the deadband	Q ₃	5940	-5940	VAR
Reactive power absorption setting	Q ₄	0	-5940	VAR



Bruce Mahrenholz, Director North American Certification Program
 UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20180510-E479199
Report Reference E479199-20180510
Issue Date 2018-June-14

SA13 Volt/Var Mode (VV) extent of curve range settings Model: SUN2000-10KTL-USL0 240V				
Settings		Qmax Values - Maximums	Qmin Values - Minimums	Units
Reactive power production setting	Q ₁	6000	0	VAR
Reactive power absorption setting at the left edge of the deadband	Q ₂	6000	-6000	VAR
Reactive power absorption setting at the right edge of the deadband	Q ₃	6000	-6000	VAR
Reactive power absorption setting	Q ₄	0	-6000	VAR

SA13 Volt/Var Mode (VV) extent of curve range settings Model: SUN2000-10KTL-USL0 208V				
Settings		Qmax Values - Maximums	Qmin Values - Minimums	Units
Reactive power production setting	Q ₁	5220	0	VAR
Reactive power absorption setting at the left edge of the deadband	Q ₂	5220	-5220	VAR
Reactive power absorption setting at the right edge of the deadband	Q ₃	5220	-5220	VAR
Reactive power absorption setting	Q ₄	0	-5220	VAR



Bruce Mahrenholz, Director North American Certification Program
 UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20180510-E479199
Report Reference E479199-20180510
Issue Date 2018-June-14

SA13 Volt/Var Mode (VV) extent of curve range settings Model: SUN2000-9KTL-USL0 240V				
Settings		Qmax Values - Maximums	Qmin Values - Minimums	Units
Reactive power production setting	Q ₁	5400	0	VAR
Reactive power absorption setting at the left edge of the deadband	Q ₂	5400	-5400	VAR
Reactive power absorption setting at the right edge of the deadband	Q ₃	5400	-5400	VAR
Reactive power absorption setting	Q ₄	0	-5400	VAR

SA13 Volt/Var Mode (VV) extent of curve range settings Model: SUN2000-9KTL-USL0 208V				
Settings		Qmax Values - Maximums	Qmin Values - Minimums	Units
Reactive power production setting	Q ₁	4680	0	VAR
Reactive power absorption setting at the left edge of the deadband	Q ₂	4680	-4680	VAR
Reactive power absorption setting at the right edge of the deadband	Q ₃	4680	-4680	VAR
Reactive power absorption setting	Q ₄	0	-4680	VAR

Settings		Maximum	Minimum	Units
The voltage at Q ₁	V ₁	103 %	82 %	%Vnom
The voltage at Q ₂	V ₂	105 %	92 %	%Vnom
The voltage at Q ₃	V ₃	108 %	95 %	%Vnom
The voltage at Q ₄	V ₄	118 %	97 %	%Vnom



Bruce Mahrenholz, Director North American Certification Program
 UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20180510-E479199
Report Reference E479199-20180510
Issue Date 2018-June-14

SA14 Frequency-Watt (FW) extent of curve range settings

Settings	Frequency		Power level	
Low end of the adjustment range of the start of the curtailment function	F _{start_min}	60.017	100 %	%Watts
High end of the adjustment range of the start of the curtailment function	F _{start_max}	65.0	100 %	%Watts
Frequency droop	kof	0.02	0.1	fPU/(WPU change)

SA15 Volt-Watt (VW) extent of curve range settings

Settings	Volts		Power level	
Low end of the adjustment range of the start of the curtailment function	V _{start_min}	105 %	100%	%Watts
High end of the adjustment range of the start of the curtailment function	V _{start_max}	109 %	100 %	%Watts
Low end of the adjustment range of the endpoint of the curtailment function	V _{stop_min}	106%	0 %	%Watts
High end of the adjustment range of the endpoint of the curtailment function	V _{stop_max}	110 %	0 %	%Watts



Bruce Mahrenholz, Director North American Certification Program
 UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

